



### NOTES:

1. Posts shall be 4" galvanized steel pipe, ASA schedule 40, filled with concrete.
2. Posts shall be given 2 coats of exterior yellow paint. Paint shall be heavy-duty industrial metal enamel.
3. Location and number of posts shall be as shown on plans approved by the City Engineer.
4. Posts shall be used for protection of fire hydrants, above ground piping exposed to traffic and underground vaults which are not designed for traffic loads. Posts will not be required where curbs or parking barriers are effectively located to protect the facility.

REV	DATE	APPROVED	DESIGN
			DRAWN
			CHECKED
			APPROVED BY
			<i>Carol M. M. [Signature]</i>
			CITY ENGINEER
			DATE <i>10/19/91</i>

CITY OF MILPITAS  
PUBLIC WORKS DEPARTMENT  
ENGINEERING DIVISION  
STANDARD DRAWING

## TRAFFIC BARRIER POSTS

NO. 206

C 8-15-67

W

S

SHEET 1 OF 1